



Fire Prevention Division

11465 W. Civic Center Drive
Avondale, Arizona 85323
Phone: (623) 333-6140
Fax: (623) 333-0401
Website: www.avondale.org

SUPPLEMENTAL RULES & REGULATIONS

Number:	08-508.5.1.2		
Subject:	Fire Hydrants in Litchfield Park Service Company (LPSCO) Service Area		
Code:	2003 International Fire Code	Code Section:	508.5.1.2
Effective Date:	June 16, 2008	Issued by:	Fire Marshal Roger Parker 
Revision Date:	NA	Issued by:	NA
Supersedes:	NA	Date:	NA

AUTHORITY:

§104.1 of the 2003 International Fire Code authorizes the fire marshal to render interpretations of the fire code, and to adopt policies, procedures, rules and regulations in order to clarify the application of its provisions.

PURPOSE:

To clarify the intent of the fire code amendment and establish rules and regulations regarding requirements for fire hydrants installed in the Litchfield Park Service Company (LPSCO) service area.

SCOPE:

This regulation covers all facilities, buildings, or uses within the City of Avondale after the effective date.

GENERAL:

The 2003 International Fire Code §903.2.2, as amended by the City of Avondale states:

All new fire hydrants are required to be "wet-barrel" type hydrants. For commercial and/or multi-family developments, the Clow Model #860 wet barrel hydrant or equivalent with LBI Model #400 breakaway check valve or equivalent is required. For single-family residential areas, the Clow Model #850 wet barrel hydrant with LBI Model #400 breakaway check valve or equivalent is required. All threads will be national standard threads.

SUPPLEMENTAL RULE OR REGULATION:

Fire hydrants installed in the Litchfield Park Service Company (LPSCO) area shall be in accordance with the requirements of the Litchfield Park Service Company (LPSCO). All threads shall be national standard threads.